

## **IMPORTANT PRODUCT SAFETY NOTICE**

### **STOP SHIP/STOP SALE**

January 26, 2018

#### **Kidde Dual Sensor (Photoelectric and Ionization) Smoke Alarms**

Dear Valued Customer:

This bulletin contains important information regarding a potential safety issue impacting Kidde's dual sensor smoke alarms that contain both a photoelectric and ionization smoke sensor. As we are committed to the safety and quality of our products and out of an abundance of caution, we are stopping shipment of the following models, and request that you stop selling these models, effective immediately:

PI2010 (AC/hardwired)  
PI9010 (DC/battery powered)

We are working closely with the U.S. Consumer Product Safety Commission (CPSC) and Health Canada on this issue to initiate a voluntary recall of these products.

#### **ADDITIONAL DETAILS:**

**Reason:** During the manufacturing process, a yellow protective cap may have been left on one of the two smoke sensors in a small number of cases, which could compromise the smoke alarms' ability to detect smoke.

**Action:** Effective immediately, Kidde requests that you segregate, hold and stop sale of the affected models. Kidde is prepared to issue an RMA number for the potentially affected units.

**Affected Models:** Two models of Kidde dual sensor smoke alarms with manufacture dates between September 10, 2016 and Oct. 13, 2017 are potentially affected. The potentially affected models include PI2010 and PI9010.

**Models not affected:** No other models of smoke alarms, carbon monoxide alarms or combination smoke and carbon monoxide alarms are affected


**Replacement:** The alarm has been redesigned and new SKUs have been created and Kidde anticipates being able to ship these new items by February 2, 2018. The cross reference of old to new SKUs is below:

Model	Affected Product		New Product / Replacement SKU	
	SKU	UPC	SKU	UPC
PI2010	21007915	0-47871-07915-5	21007915-N	0-47871-27130-6
	21026061	0-47871-26061-4	21026061-N	0-47871-26161-1
	21027130	0-47871-07915-5	21027130-N	0-47871-27130-6
PI9010	21007385	0-47871-42007-0	21007385-N	0-47871-42017-9
	21009410	0-47871-09410-3	No Replacement SKU	
	44200702	0-47871-42007-0	44200702-N	0-47871-42017-9
	21026062	0-47871-26062-1	21026062-N	0-47871-26162-8
	21026400	0-47871-09594-0	No Replacement SKU	
	21027166	0-47871-09410-3	21027166-N	0-47871-27166-5
	21027563	0-47871-09594-0	21027563-N	0-47871-27563-2

Please contact your regional sales manager or customer service representative for an RMA or additional return information. We will continue to provide regular updates as available.

We appreciate your cooperation and patience in this matter.

Sincerely,



Paul Fraipont  
 President, Walter Kidde Portable Equipment Company